N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12030-16-3639
State Number
22271

EQUIPMENT INSPECTED

State Number: **22271**
Capacity: 2100
Landings: 3
Volts: 240

Type of Unit: Passenger
Manuf: TKE
Installed: 12/17/2009
Complied:

Floor to Floor: 1 to 3
Speed: 50
Rope Size: 0
Entrances: 1

OWNER
MR MARK GRAY
108 N ELM STREET
GREENSBORO, NC, 27401

OCCUPANT
WASHINGTON DOWNTOWN OFB
158 E MAIN STREET
WASHINGTON, NC, 27889

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
01/30/2012	Removed	Not Issued	16 - Moore	BEAUFORT

7

VIOLATIONS

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Could not get in bldg.

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
MR MARK GRAY
108 N ELM STREET
GREENSBORO, NC, 27401