



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12039-36-275
State Number
15056

EQUIPMENT INSPECTED

State Number: 15056	Type of Unit: Passenger	Floor to Floor: B to 9
Capacity: 3500	Manuf: WEBSTER	Speed: 200
Landings: 10	Installed: 07/30/1993	Rope Size: 5/8
Volts: 480	Complied: 08/09/1993	Entrances: 1

OWNER

LAB CORP
ATTN LORRIE FLINCHUM
BURLINGTON, NC, 27215

OCCUPANT

LAB CORP "AB&T BDLG"
358 S MAIN ST
BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date 02/08/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

none found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: LORIE FLINCHUM 336-436-7777

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

LAB CORP
ATTN LORRIE FLINCHUM
BURLINGTON, NC, 27215