



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12039-7-461
State Number
H2257

EQUIPMENT INSPECTED

State Number: H2257	Type of Unit: Hand Lift	Floor to Floor: 1 to 2
Capacity: 750	Manuf: TK	Speed: 9
Landings: 2	Installed: 08/01/2011	Rope Size:
Volts: 115	Complied:	Entrances: 2
OWNER	OCCUPANT	
THREE FORKS BAPTIST CHURCH	THREE FORKS BAPTIST CHURCH	
4865 THREE FORKS CHURCH ROAD	4865 THREE FORKS CHURCH ROAD	
TAYLORSVILLE, NC, 28681	TAYLORSVILLE, NC, 28681	

INSPECTION INFORMATION

Inspection Date 02/08/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 7 - Hoffman	County ALEXANDER
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

2

VIOLATIONS

a.18.1 REPLACE MISSING SCREWS IN THE SIDE PANEL OF LIFT

Items must be corrected by: 03/09/2012

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Three Forks Baptist 828-632-7634

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

THREE FORKS BAPTIST CHURCH
4865 THREE FORKS CHURCH ROAD
TAYLORSVILLE, NC, 28681