



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12040-36-5482
State Number
19932

EQUIPMENT INSPECTED

State Number: 19932	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 95
Landings: 2	Installed: 06/26/2001	Rope Size:
Volts: 208	Complied: 06/26/2001	Entrances: 1
OWNER	OCCUPANT	
PARKER OFFICE BLDG	STATE FARM INS	
3102 S CHURCH ST	3102 S CHURCH ST	
BURLINGTON, NC, 27216	BURLINGTON, NC, 27216	

INSPECTION INFORMATION

Inspection Date 02/09/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

none found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Nixon Parker 336-235-0978

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

PARKER OFFICE BLDG
3102 S CHURCH ST
BURLINGTON, NC, 27216