



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12041-36-2638
State Number
23959

EQUIPMENT INSPECTED

State Number: 23959	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: OTIS	Speed: 100
Landings: 3	Installed: 12/11/2006	Rope Size: 0
Volts: 208	Complied: 12/11/2006	Entrances: 1

OWNER
SLATTER MNG SERVICES INC
4125 G WALKER AVE
GREENSBORO, NC, 27407

OCCUPANT
WINDEMERE CONDOS
3010 WINSTON DR
BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date 02/10/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

8.6.4.7.4 Remove the water from the pit floor and clean

Items must be corrected by: 03/11/2012

Elevator Name: WANDA 336-272-0641

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: TINA TILLMAN 336-272-0641

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SLATTER MNG SERVICES INC
4125 G WALKER AVE
GREENSBORO, NC, 27407