N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12041-48-1762
State Number
27382

EQUIPMENT INSPECTED

State Number: **27382**
Capacity: 4500
Landings: 4
Volts: 480

Type of Unit: Passenger
Manuf: OTIS
Installed: 02/17/2011
Complied: 02/17/2011

Floor to Floor: 1 to 4
Speed: 125
Rope Size:
Entrances: 1

OWNER
NOVANT HEALTH
119 BROOKSTOWN AVENUE
WINSTON SALEM, NC, 27101

OCCUPANT
NOVANT HOSPITAL - BRUNSWICK
550 OCEAN HWY 17
BOLIVIA, NC, 28422

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
02/10/2012	Routine	Re-issued	48 - Martin	BRUNSWICK	10

VIOLATIONS

n/a No violations found

Elevator Name: # 7

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: HOWIE

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
NOVANT HEALTH
119 BROOKSTOWN AVENUE
WINSTON SALEM, NC, 27101