



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12044-48-1929
State Number
23191

EQUIPMENT INSPECTED

State Number: 23191	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2000	Manuf: CANTON	Speed: 100
Landings: 3	Installed: 08/22/2005	Rope Size:
Volts: 240	Complied: 08/22/2005	Entrances: 1
OWNER	OCCUPANT	
LAWRENCE COASTAL REAL ESTATE	SOUTHPORT CONDOS BLDG #4	
5003 O'QUINN BLVD.	612 WEST BROWN ST	
SOUTHPORT, NC, 28461	SOUTHPORT, NC, 28461	

INSPECTION INFORMATION

Inspection Date 02/13/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

- 8.6.4.13.1[f] Properly maintain hangers, tracks, door rollers, up-thrusts, and door safety retainers, where required. CAR DOOR AND HOISTWAY DOORS SQUEAK.
- 5.1.21.1 Put the in car alarm bell in working order.

Items must be corrected by: 03/04/2012

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

LAWRENCE COASTAL REAL ESTATE
5003 O'QUINN BLVD.
SOUTHPORT, NC, 28461