



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12045-36-4245
State Number
15614

EQUIPMENT INSPECTED

State Number: 15614	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 4500	Manuf: OTIS	Speed: 125
Landings: 3	Installed: 06/16/1995	Rope Size:
Volts: 480	Complied: 10/25/2000	Entrances: 1
OWNER	OCCUPANT	
ALAMANCE REGIONAL MEDICAL CTR	MEDICAL ARTS CENTER	
1230 HUFFMAN MILL ROAD	1236 HUFFMAN MILL RD	
BURLINGTON, NC, 27216	BURLINGTON, NC, 27217	

INSPECTION INFORMATION

Inspection Date 02/14/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

None found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Don Scott 336-538-7776

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALAMANCE REGIONAL MEDICAL CTR
1230 HUFFMAN MILL ROAD
BURLINGTON, NC, 27216