



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12046-16-2848
State Number
20670

EQUIPMENT INSPECTED

State Number: 20670	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 4	Installed: 05/15/2002	Rope Size: 0
Volts: 208	Complied:	Entrances: 1
OWNER	OCCUPANT	
DILIP DESAI LODGENG ASSOC	HAMPTON INN	
CHEASAPEAKE, VA	2085 W. 15TH STREET	
CHEASAPEAKE, VA, 23320	WASHINGTON, NC, 27889	

INSPECTION INFORMATION

Inspection Date 02/15/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 16 - Moore	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

7

VIOLATIONS

n/a No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Brendan Morris / Manager

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

DILIP DESAI LODGENG ASSOC
CHEASAPEAKE, VA
CHEASAPEAKE, VA, 23320