N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12046-48-5341
State Number
21687

EQUIPMENT INSPECTED

State Number: **21687**
Capacity: 2100
Landings: 0
Volts: 0

Type of Unit: Passenger
Manuf: RENAME
Installed: 05/29/2003
Complied: 06/11/2003

Floor to Floor: . to .
Speed: 0
Rope Size: .
Entrances: 0

OWNER
THE WOODLANDS @ CROW CREEK
10255 BEACH DR SW
CALABASH, NC, 28469

OCCUPANT
CROW CREEK CONDO
250 S. CROW CREEK DR.
CALABASH, NC, 28469

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
02/15/2012	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

2.27.1.1.2 Put the in car emergency telephone in proper working order.

Items must be corrected by: 03/06/2012

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
THE WOODLANDS @ CROW CREEK
10255 BEACH DR SW
CALABASH, NC, 28469