



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12047-17-3389
State Number
14541

EQUIPMENT INSPECTED

State Number: 14541	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 4000	Manuf: SCHINDLER	Speed: 100
Landings: 2	Installed: 02/27/1992	Rope Size:
Volts: 440	Complied: 03/18/1992	Entrances: 1

OWNER

ASHEVILLE REGIONAL AIRPORT
61 TERMINAL DRIVE
FLETCHER, NC, 28732

OCCUPANT

ASHEVILLE REGIONAL AIRPORT
61 TERMINAL DRIVE
FLETCHER, NC, 28732

INSPECTION INFORMATION

Inspection Date 02/16/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 17 - White	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

note no violations.

Items must be corrected by: 02/16/2012

Elevator Name: new

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: maintenance 828-654-3249

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ASHEVILLE REGIONAL AIRPORT
61 TERMINAL DRIVE
FLETCHER, NC, 28732