



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12047-48-0433
State Number
24648

EQUIPMENT INSPECTED

| | | |
|----------------------------|----------------------------|------------------------|
| State Number: 24648 | Type of Unit: Passenger | Floor to Floor: 1 to 3 |
| Capacity: 2000 | Manuf: THYSSEN KRUPP | Speed: 55 |
| Landings: 3 | Installed: 02/01/2007 | Rope Size: 0 |
| Volts: 230 | Complied: | Entrances: 1 |
| OWNER | OCCUPANT | |
| CROW CREEK BLDG #11 | CROW CREEK - BLDG #11 | |
| 395 SOUTH CROW CREEK DRIVE | 395 SOUTH CROW CREEK DRIVE | |
| CALABASH, NC, 28467 | CALABASH, NC, 28467 | |

INSPECTION INFORMATION

| | | | | |
|-------------------------------|----------------------------|---------------------------------|--------------------------|---------------------|
| Inspection Date 02/16/2012 | Type Inspection Routine | Certificate Status Re-issued | Inspector 48 - Martin | County BRUNSWICK |
|-------------------------------|----------------------------|---------------------------------|--------------------------|---------------------|

10

VIOLATIONS

2.26.2.7 Put the pit stop switch in working order. LOSE COVER ON PIT STOP SW., SCREW MISSING

Items must be corrected by: 03/07/2012

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Unavailable

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CROW CREEK BLDG #11
395 SOUTH CROW CREEK DRIVE
CALABASH, NC, 28467