



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12047-48-462
State Number
24650

EQUIPMENT INSPECTED

State Number: 24650	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2000	Manuf: THYSSEN KRUPP	Speed: 55
Landings: 3	Installed: 02/01/2007	Rope Size: 0
Volts: 230	Complied:	Entrances: 1
OWNER	OCCUPANT	
THE WOODLANDS @ CROW CREEK	CROW CREEK - BLDG. #12	
10255 BEACH DR SW	395 CROW CREEK DRIVE	
CALABASH, NC, 28467	CALABASH, NC, 28467	

INSPECTION INFORMATION

Inspection Date 02/16/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

n/a No Violations Found

Items must be corrected by: 03/07/2012

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Unavailable

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

THE WOODLANDS @ CROW CREEK
10255 BEACH DR SW
CALABASH, NC, 28467