



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12048-36-2588
State Number
21423

EQUIPMENT INSPECTED

State Number: 21423	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 75
Landings: 2	Installed: 01/21/2003	Rope Size: 0
Volts: 208	Complied: 01/21/2003	Entrances: 2
OWNER	OCCUPANT	
SAMP POWELL	"LIMP IN, LEAP OUT"	
154 HUFFMAN MILL ROAD	154 HUFFMAN MILL ROAD	
BURLINGTON, NC, 27015	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 02/17/2012	Type Inspection Not Inspected	Certificate Status Not Issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------------	----------------------------------	---------------------------	--------------------

1

VIOLATIONS

8.11.2.3.1	Provide the annual no load test.
8.6.10.1	Update the monthly fire service log.
	LEFT MESSAGE WITH OWNER SAM POWELL 336--684-2943
8.6	PLACE ELEVATOR IN PROPER WORKING ORDER

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: MARGERT McCANN 336-227-9880

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SAMP POWELL
154 HUFFMAN MILL ROAD
BURLINGTON, NC, 27015