



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12058-16-0754
State Number
4141

EQUIPMENT INSPECTED

State Number: 4141	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 1200	Manuf: SOUTHERN	Speed: 50
Landings: 2	Installed: 02/17/1959	Rope Size: 0
Volts: 208	Complied: 02/17/1959	Entrances: 1
OWNER	OCCUPANT	
ORR LODGE 104	ORR LODGE 104	
PO BOX 1913	3RD BONNER STS	
WASHINGTON, NC, 27889	WASHINGTON, NC, 27889	

INSPECTION INFORMATION

Inspection Date 02/27/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 16 - Moore	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

7

VIOLATIONS

n/a No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Ray Briley

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ORR LODGE 104
PO BOX 1913
WASHINGTON, NC, 27889