N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12058-16-0835
State Number
15011

EQUIPMENT INSPECTED

State Number: **15011**
Capacity: 2000
Landings: 2
Volts: 220

Type of Unit: Passenger
Manuf: US ELEVATOR
Installed: 11/24/1993
Complied: 11/24/1993

Floor to Floor: 1 to 2
Speed: 100
Rope Size: 0
Entrances: 1

OWNER
CITY OF WASHINGTON
102 E 2ND STREET
WASHINGTON, NC, 27889

OCCUPANT
BROWN LIBRARY
122 VAN NORDEN ST
WASHINGTON, NC, 27889

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
02/27/2012	Routine	Re-issued	16 - Moore	BEAUFORT

7

VIOLATIONS

8.6.4.15 Take steps to place the car emergency light in proper working order.

Items must be corrected by: 03/28/2012

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Gloria Moore

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
CITY OF WASHINGTON
102 E 2ND STREET
WASHINGTON, NC, 27889