



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**12061-24-0075**  
State Number  
**23783**

### EQUIPMENT INSPECTED

State Number: <b>23783</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: IECA	Speed: 100
Landings: 3	Installed: 03/13/2006	Rope Size: .
Volts: 208	Complied:	Entrances: 1

#### OWNER

ASHEVILLE BOARD OF REALTORS  
37 MONTFORD AVE  
ASHEVILLE, NC, 28801

#### OCCUPANT

ASHEVILLE BOARD OF REALTORS  
37 MONTFORD AVE  
ASHEVILLE, NC, 28801

### INSPECTION INFORMATION

Inspection Date 03/01/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 24 - Moore	County BUNCOMBE	11 B
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

### VIOLATIONS

- 2.27.1.1.2 Put the in car emergency telephone in proper working order. 10 Days Notice !!!!!!!!!!!!!!! Can not be thru a switchboard or extension. You must be able to call directly back to the elevator.
- 8.6.5.16.5 Perform the full load 5 yr overspeed valve test and document with a tag indicating the date and the person or firm performing the test. Tag is to be placed on the controller or valve.

Items must be corrected by: 03/31/2012

Elevator Name: ELEVATOR # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: David West / 828-255-8505

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ASHEVILLE BOARD OF REALTORS  
37 MONTFORD AVE  
ASHEVILLE, NC, 28801