N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12072-48-4332
State Number
21808

EQUIPMENT INSPECTED

State Number: **21808**
Capacity: 3000
Landings: 4
Volts: 208

Type of Unit: Passenger
Manuf: THYSSEN KRUPP
Installed: 07/31/2003
Complied: 07/31/2003

Floor to Floor: 1 to 4
Speed: 125
Rope Size: 0
Entrances: 1

OWNER
CAM
P.O. BOX 8126
OCEAN ISLE BEACH, NC, 28469

OCCUPANT
ISLANDER RESORT - BLDG. #28
3 JAN STREET
OCEAN ISLE BEACH, NC, 28469

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
03/12/2012	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

8.6.4.7.1 Clean the elevator pit.

Items must be corrected by: 04/01/2012

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
CAM
P.O. BOX 8126
OCEAN ISLE BEACH, NC, 28469