



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**12075-48-0972**  
State Number  
**21072**

EQUIPMENT INSPECTED

State Number: <b>21072</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2000	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 3	Installed: 05/23/2002	Rope Size:
Volts: 208	Complied: 05/23/2002	Entrances: 1
OWNER	OCCUPANT	
SAGAR PATEL & WES WARD	ECONOLODGE INN & SUITES	
4646 EAST COAST LANE NW	4646 EAST COAST LANE NW	
SHALOTTE, NC, 28470	SHALOTTE, NC, 28470	

INSPECTION INFORMATION

Inspection Date 03/15/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.27.1.1.2	Put the in car emergency telephone in proper working order.
8.6.4.7.4	Remove the water from the pit floor.
N/A	PROVIDE LIGHT SW. COVER IN PIT

Items must be corrected by: 04/04/2012

Elevator Name: #1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: SAGER PATEL

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SAGAR PATEL & WES WARD  
4646 EAST COAST LANE NW  
SHALOTTE, NC, 28470