N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12080-48-1139
State Number
26232

EQUIPMENT INSPECTED

State Number: **26232**
Capacity: 2500
Landings: 2
Volts: 200

Type of Unit: Passenger
Manuf: TKE
Installed: 01/28/2009
Complied: 01/28/2009

Floor to Floor: 1 to 2
Speed: 135
Rope Size:
Entrances: 1

OWNER
OAK ISLAND TOWN HALL
4601 E. OAK ISLAND DR.
OAK ISLAND, NC, 28465

OCCUPANT
SOUTH HARBOR VILLAGE FIRE DEPARTMENT
4151 VANESSA DRIVE
OAK ISLAND, NC, 28465

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
03/20/2012	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

8.11.2.2.2 Perform the annual no load safety test

Items must be corrected by: 04/19/2012

Elevator Name: #1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: JAMES

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
OAK ISLAND TOWN HALL
4601 E. OAK ISLAND DR.
OAK ISLAND, NC, 28465