N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12080-48-1714
State Number
24779

EQUIPMENT INSPECTED

State Number: **24779**
Capacity: 2100
Landings: 3
Volts: 208

Type of Unit: Passenger
Manuf: THYSSEN KRUPP
Installed: 05/17/2007
Complied: 05/17/2007

Floor to Floor: 1 to 3
Speed: 135
Rope Size: 0
Entrances: 1

OWNER
STATION DEVELOPMENT CORP.
5001 UNIT J O'QUINN BLVD.
SOUTHPORT,NC, NC, 28461

OCCUPANT
SOUTH HARBOR
4132 VANESSA DRIVE
OAK ISLAND, NC, 28429

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
03/20/2012	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

8.6.8.9 Signs. Caution signs shall be provided. Damaged or missing signs shall be replaced. 3RD. FL.

Items must be corrected by: 04/09/2012

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
STATION DEVELOPMENT CORP.
5001 UNIT J O'QUINN BLVD.
SOUTHPORT,NC, NC, 28461