



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12110-17-1258
State Number
17494

EQUIPMENT INSPECTED

State Number: 17494	Type of Unit: Passenger	Floor to Floor: G to 2
Capacity: 2100	Manuf: ACE	Speed: 100
Landings: 3	Installed: 08/05/1998	Rope Size:
Volts: 208	Complied: 08/05/1998	Entrances: 1
OWNER	OCCUPANT	
ARDEN FIRST BAPTIST CHURCH	ARDEN FIRST BAPTIST CHURCH	
3839 SWEETEN CREEK RD	3839 SWEETEN CREEK RD	
ARDEN, NC, 28704	ARDEN, NC, 28704	

INSPECTION INFORMATION

Inspection Date 04/19/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 17 - White	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

8.11.3	Perform the 5 year full load test on the pit overspeed valve.
note	Test all elevator smoke detectors for 2012.
nec	Repair top of car fan cover exposed electrical wires.
8.6.4	Repair car interior lower back wall stainless steel trim.
8.6.1.7.2	Provide a test data tag for controller.

Items must be corrected by: 05/19/2012

Elevator Name: 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: office 828-684-6780

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ARDEN FIRST BAPTIST CHURCH
3839 SWEETEN CREEK RD
ARDEN, NC, 28704