



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**12110-48-411**  
State Number  
**25843**

#### EQUIPMENT INSPECTED

State Number: <b>25843</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: SCHINDLER	Speed: 100
Landings: 2	Installed: 06/06/2008	Rope Size:
Volts: 240	Complied: 06/06/2008	Entrances: 1
OWNER	OCCUPANT	
CITY OF SOUTHPORT	FRANKLIN SQUARE ART GALLERY	
201 E. MOORE STREET	130 WEST STREET	
SOUTHPORT, NC, 28461	SOUTHPORT, NC, 28461	

#### INSPECTION INFORMATION

Inspection Date 04/19/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

#### VIOLATIONS

2.27.3.1 Put the Phase I fire service feature in proper working order. ALARM BUZZER INOPERATIVE.

Items must be corrected by: 05/19/2012

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: MANAGEMENT

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CITY OF SOUTHPORT  
201 E. MOORE STREET  
SOUTHPORT, NC, 28461