



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12114-16-3888
State Number
N7.1

EQUIPMENT INSPECTED

State Number: N7.1	Type of Unit: Freight	Floor to Floor: B to 3
Capacity: 1500	Manuf: WESTBROOK	Speed: 100
Landings: 5	Installed: 05/21/1975	Rope Size: 5/8
Volts: 220	Complied: 05/21/1975	Entrances: 2
OWNER	OCCUPANT	
NORMAN MANNING	PHILLIPS WRIGHT FURNITURE CO.	
246 W MAIN ST.	246 W MAIN ST	
WASHINGTON, NC, 27889	WASHINGTON, NC, 27889	

INSPECTION INFORMATION

Inspection Date 04/23/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 16 - Moore	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

7

VIOLATIONS

n/a No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Fredrick Switzer

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

NORMAN MANNING
246 W MAIN ST.
WASHINGTON, NC, 27889