



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12114-54-3592
State Number
17569

EQUIPMENT INSPECTED

State Number: 17569	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: US ELEVATOR	Speed: 100
Landings: 2	Installed: 04/24/1998	Rope Size:
Volts: 230	Complied: 05/04/1998	Entrances: 1
OWNER	OCCUPANT	
DR. STEVEN FERGUSON	E. CAR. GERIATRIC ASSOC & FAM CARE CTR	
115 LUTHER BROWN ROAD	105 COMMERCE STREET	
COLERAIN, NC, 27924	POWELLSVILLE, NC, 27967	

INSPECTION INFORMATION

Inspection Date 04/23/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 54 - Green	County BERTIE
-------------------------------	----------------------------	---------------------------------	-------------------------	------------------

8

VIOLATIONS

NEC 620.85 Put the machine room GFI in working order.

8.6.4.8.2 Articles or materials not necessary for the maintenance or operation of the elevator shall not be stored in machine rooms and machinery spaces.

2.14.7.1.3 Put the in car emergency light in working order.

5.1.21.1 Put the in car alarm bell in working order.

8.11.3.2.1 Perform the annual relief valve test

NEC 620.85 Put the car top GFI in working order.

Items must be corrected by: 05/23/2012

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: STEPHEN FERGUSON

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

DR. STEVEN FERGUSON
115 LUTHER BROWN ROAD
COLERAIN, NC, 27924