



INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**12121-48-0366**  
State Number  
**27592**

EQUIPMENT INSPECTED

State Number: <b>27592</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2000	Manuf: TKE	Speed: 100
Landings: 3	Installed: 10/20/2010	Rope Size:
Volts: 208	Complied: 10/20/2010	Entrances: 1
OWNER	OCCUPANT	
VILLAGE PARK PROPERTY OWNER ASSOCIATION	VILLAGE PARK CONDOMINIUMS	
1842 BANKING ST.	7825 HIGH MARKET STREET	
GREENSBORO, NC, 27408	SUNSET BEACH, NC, 28468	

INSPECTION INFORMATION

Inspection Date 04/30/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

- 2.27.1.1.2 Put the in car emergency telephone in proper working order.
- 8.6.4.8.2 Remove all materials from machine room (machinery space) not pertaining to the maintenance or operation of the elevator(s).
- 8.6.5.5.2 Empty the drain bucket in the pit.

Items must be corrected by: 05/30/2012

Elevator Name: #1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

VILLAGE PARK PROPERTY OWNER ASSOCIATION  
1842 BANKING ST.  
GREENSBORO, NC, 27408