N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12121-48-1351
State Number
25287

EQUIPMENT INSPECTED

State Number: **25287**
Capacity: 2000
Landings: 3
Volts: 208

Type of Unit: Passenger
Manuf: TKE
Installed: 02/06/2008
Complied: 02/06/2008

Floor to Floor: 1 to 3
Speed: 125
Rope Size:
Entrances: 1

OWNER
VILLAGE PARK PROPERTY OWNERS ASSOCIATION
1482 BANKING ST.
GREENSBORO, NC, 27408

OCCUPANT
VILLAGE PARK CONDOS
7821 HIGH MARKET ST.
SUNSET BEACH, NC, 28468

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
04/30/2012	Routine	Re-issued	48 - Martin	BRUNSWICK	10

VIOLATIONS

8.6.4.7.1	Clean the elevator pit.
8.6.4.8.1	Clean the elevator machine room.
2.27.1.1.2	Put the in car emergency telephone in proper working order.

Items must be corrected by: 05/30/2012

Elevator Name: BLDG 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
VILLAGE PARK PROPERTY OWNERS ASSOCIATION
1482 BANKING ST.
GREENSBORO, NC, 27408