



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12123-24-2611
State Number
22267

EQUIPMENT INSPECTED

State Number: 22267	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2100	Manuf: VERTX	Speed: 90
Landings: 7	Installed: 03/22/2005	Rope Size:
Volts: 208	Complied: 05/02/2005	Entrances: 2

OWNER

37 HIAWASSEE CONDOMINIUM ASSOC. INC.
37 HIAWASSEE STREET
ASHEVILLE, NC, 28801

OCCUPANT

37 HIAWASSEE CONDOMINIUM ASSOC. INC.
37 HIAWASSEE STREET
ASHEVILLE, NC, 28801

INSPECTION INFORMATION

Inspection Date 05/02/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 24 - Moore	County BUNCOMBE	11 B
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

8.6.5.12 Low oil protection shall be maintained to operate in compliance with the applicable code. Car goes on low oil time before reaching RE.

Items must be corrected by: 06/01/2012

Elevator Name: ELEVATOR # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Laura Dyer / 828-277-8685

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

37 HIAWASSEE CONDOMINIUM ASSOC. INC.
37 HIAWASSEE STREET
ASHEVILLE, NC, 28801