



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12128-36-5983
State Number
21832

EQUIPMENT INSPECTED

State Number: 21832	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 80
Landings: 2	Installed: 08/18/2003	Rope Size: 0
Volts: 208	Complied: 08/18/2003	Entrances: 1

OWNER

GRAHAM PRESBYTERIAN CHURCH
216 W HARDEN STREET
GRAHAM, NC, 27213

OCCUPANT

GRAHAM PRESBYTERIAN CHURCH
216 W HARDEN STREET
GRAHAM, NC, 27213

INSPECTION INFORMATION

Inspection Date 05/07/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: MILDRED PRICE 336-226-4747

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

GRAHAM PRESBYTERIAN CHURCH
216 W HARDEN STREET
GRAHAM, NC, 27213