



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12128-48-3024
State Number
20608

EQUIPMENT INSPECTED

State Number: 20608	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: OTIS	Speed: 125
Landings: 3	Installed: 04/05/2002	Rope Size:
Volts: 480	Complied:	Entrances: 1
OWNER	OCCUPANT	
BRUNSWICK CO OPERATION SERVICES	BRUNSWICK CO COURTHOUSE	
PO BOX 249	45 COURTHOUSE DR	
BOLIVIA, NC, 28422	BOLIVIA, NC, 28422	

INSPECTION INFORMATION

Inspection Date 05/07/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

n/a No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: JAMES CARTER

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BRUNSWICK CO OPERATION SERVICES
PO BOX 249
BOLIVIA, NC, 28422