N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12128-48-3874
State Number
20609

EQUIPMENT INSPECTED

State Number: **20609**
Capacity: 2500
Landings: 3
Volts: 480

Type of Unit: Passenger
Manuf: OTIS
Installed: 04/05/2002
Complied:

Floor to Floor: 1 to 3
Speed: 125
Rope Size:
Entrances: 1

OWNER
BRUNSWICK CO OPERTION SERVICES
PO BOX 249
BOLIVIA, NC, 28422

OCCUPANT
BRUNSWICK CO COURTHOUSE
45 COURTHOUSE DR
BOLIVIA, NC, 28422

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
05/07/2012	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

n/a No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: JAMES CARTER

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
BRUNSWICK CO OPERTION SERVICES
PO BOX 249
BOLIVIA, NC, 28422