



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12131-24-283
State Number
10537

EQUIPMENT INSPECTED

State Number: 10537	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: GENERAL	Speed: 100
Landings: 2	Installed: 06/15/1983	Rope Size:
Volts: 208	Complied: 07/05/1983	Entrances: 1
OWNER	OCCUPANT	
ASHEVILLE CITY SCHOOLS	LUCY HERRING ADMIN BLDG	
PO BOX 7347	85 MOUNTAIN STREET	
ASHEVILLE, NC, 28802	ASHEVILLE, NC, 28801	

INSPECTION INFORMATION

Inspection Date 05/10/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 24 - Moore	County BUNCOMBE	11 B
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

2.14.7.1.3	Put the in car emergency light & alarm in working order.
2.7.3.4.1(b)	Provide a self closing, self locking machine room door. Door latch won't lock after door has closed.

Items must be corrected by: 06/09/2012

Elevator Name: ELEVATOR # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Dwayne Taylor / 828-350-7000

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ASHEVILLE CITY SCHOOLS
PO BOX 7347
ASHEVILLE, NC, 28802