



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**12135-48-0656**  
State Number  
**13648**

#### EQUIPMENT INSPECTED

State Number: <b>13648</b>	Type of Unit: Passenger	Floor to Floor: G to -
Capacity: 2500	Manuf: OTIS	Speed: 125
Landings: 4	Installed: 02/27/1990	Rope Size:
Volts: 208	Complied: 06/01/1990	Entrances: 1
OWNER	OCCUPANT	
INLET WACCHE HOA INC	INLET WACCHE ASSO	
PO BOX 6046	1916 GOOSE CREEK RD SW	
SOUTH BRUNSWICK, NC, 28470	OCEAN ISLE BEACH, NC, 28469	

#### INSPECTION INFORMATION

Inspection Date 05/14/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

#### VIOLATIONS

- 8.6.4.8.2 Remove all materials from machine room (machinery space) not pertaining to the maintenance or operation of the elevator(s).
- 8.6.1.6.5 Provide a class "ABC" fire extinguisher in the machine room or control space convenient to the access door.
- 2.27.1.1.2 Put the in car emergency telephone in proper working order.

Items must be corrected by: 06/03/2012

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

INLET WACCHE HOA INC  
PO BOX 6046  
SOUTH BRUNSWICK, NC, 28470