



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12136-48-3632
State Number
17013

EQUIPMENT INSPECTED

| | | |
|-------------------------------|-------------------------|------------------------|
| State Number: 17013 | Type of Unit: Passenger | Floor to Floor: 1 to 4 |
| Capacity: 2500 | Manuf: THYSSEN KRUPP | Speed: 150 |
| Landings: 4 | Installed: 11/24/1997 | Rope Size: |
| Volts: 480 | Complied: 01/09/1998 | Entrances: 1 |
| OWNER | OCCUPANT | |
| BENCHMARK MANAGEMENT | WINDJAMMER CONDO | |
| C/O JANE WHIELDON | 27 W 2ND ST | |
| NORTH MYRTLE BEACH, SC, 29597 | OCEAN ISLE, NC, 28469 | |

INSPECTION INFORMATION

| | | | | |
|-------------------------------|----------------------------|---------------------------------|--------------------------|---------------------|
| Inspection Date 05/15/2012 | Type Inspection Routine | Certificate Status Re-issued | Inspector 48 - Martin | County BRUNSWICK |
|-------------------------------|----------------------------|---------------------------------|--------------------------|---------------------|

10

VIOLATIONS

N/A EXCESSIVLY LONG DOOR OPEN TIME [INTERMITTENT].

Items must be corrected by: 06/04/2012

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BENCHMARK MANAGEMENT
C/O JANE WHIELDON
NORTH MYRTLE BEACH, SC, 29597