



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12138-36-1242
State Number
24959

EQUIPMENT INSPECTED

State Number: 24959	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 4500	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 3	Installed: 08/21/2007	Rope Size:
Volts: 480	Complied:	Entrances: 1
OWNER	OCCUPANT	
ALAMANCE COMMUNITY COLLEGE	ALAMANCE CC ALLIED HEALTH/PHY SCIENCE	
1247 JIMMIE KERR ROAD	1247 JIMMY KERR RD	
GRAHAM, NC, 27253	GRAHAM, NC, 27253	

INSPECTION INFORMATION

Inspection Date 05/17/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

- 2.27.1.1.2 Put the in car emergency telephone in proper working order.NEED PROPER IDENTIFICATION FOR LOCATION AND CALL BACK NUMBER
WHEN CALLINNG BACK INTO ELEVATOR.
- 8.6.4.13.1[i] Properly maintain door restrictors.

Items must be corrected by: 06/16/2012

Elevator Name: Health/Phy Science

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into
complainace with current codes.

Violations pointed out to: Eric (336) 578-2002

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALAMANCE COMMUNITY COLLEGE
1247 JIMMIE KERR ROAD
GRAHAM, NC, 27253