N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12144-36-1631
State Number
19724

EQUIPMENT INSPECTED

State Number: **19724**
Capacity: 2100
Landings: 3
Volts: 208

Type of Unit: Passenger
Manuf: MIM ELE
Installed: 03/14/2001
Complied: 03/27/2001

Floor to Floor: 1 to 3
Speed: 100
Rope Size:
Entrances: 1

OWNER
CAROLINA PROPERTIES HOLDINGS
200 B N MAIN STREET
DURHAM, NC, 27701

OCCUPANT
CAROLINA PROPERTIES HOLDINGS
200B N MAIN ST
GRAHAM, NC, 27253

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
05/23/2012	Routine	Re-issued	36 - Kirkman	ALAMANCE

1

VIOLATIONS

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: JASON COX 919-687-3506 Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
CAROLINA PROPERTIES HOLDINGS
200 B N MAIN STREET
DURHAM, NC, 27701