



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12144-48-2053
State Number
23157

EQUIPMENT INSPECTED

State Number: 23157	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: SCHINDLER	Speed: 125
Landings: 2	Installed: 08/25/2005	Rope Size:
Volts: 208	Complied: 09/21/2005	Entrances: 1
OWNER	OCCUPANT	
MANTHBURG LLC	SOUTHPORT MEDICAL OFFICE	
8295 SPRINGS RD	1029 NORTH HOWE STREET	
WARRENTON, VA, NC, 20186	SOUTHPORT, NC, 28461	

INSPECTION INFORMATION

Inspection Date 05/23/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

n/a No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: DEBORA RUST

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

MANTHBURG LLC
8295 SPRINGS RD
WARRENTON, VA, NC, 20186