N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12163-17-1036
State Number
6775

EQUIPMENT INSPECTED

State Number: **6775**
Capacity: 2500
Landings: 8
Volts: 550

Type of Unit: Passenger
Manuf: WESTINGHOUSE
Installed: 11/24/1970
Complied: 02/02/1971

Floor to Floor: G to 7
Speed: 350
Rope Size: 1/2
Entrances: 1

OWNER
ASHEVILLE BUNCOMBE TECH COLL
340 VICOTRIA RD
ASHEVILLE, NC, 28801

OCCUPANT
ASHEVILLE BUNCOMBE COLL
1459 SANDHILL RD.
CANDLER, NC, 28715

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
06/11/2012	Routine	Re-issued	17 - White	BUNCOMBE	11 A

VIOLATIONS

8.6.4	Secure gear box leak repair as necessary.
rec	Provide cae emergency numbering, hall, car top, machine room.
rec	Provide a second stop switch in pit.
8.6.4	Clean car top of gear box oil.

Items must be corrected by: 07/11/2012

Elevator Name: 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: EDDIE 828-254-1921

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
ASHEVILLE BUNCOMBE TECH COLL
340 VICOTRIA RD
ASHEVILLE, NC, 28801