



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**12163-52-3229**  
State Number  
**20202**

#### EQUIPMENT INSPECTED

State Number: <b>20202</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 95
Landings: 2	Installed: 04/18/2002	Rope Size: 0
Volts: 208	Complied:	Entrances: 1
OWNER	OCCUPANT	
BEACH MOUNTAIN CLUB	BEACH MOUNTAIN CLUB	
114 CLUB HOUSE ROAD	114 CLUB HOUSE ROAD	
BEACH MOUNTAIN, NC, 28604	BEACH MOUNTAIN, NC, 28604	

#### INSPECTION INFORMATION

Inspection Date 06/11/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 52 - Sosebee	County AVERY
-------------------------------	----------------------------	---------------------------------	---------------------------	-----------------

6

#### VIOLATIONS

8.6.1.7.2	Provide the proper metal tag to the controller for all periodic test.
8.6.5.16.5	Perform the 5 year full load test on the overspeed valve.

Items must be corrected by: 07/11/2012

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Beach Mountain Club 828-387-4747

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BEACH MOUNTAIN CLUB  
114 CLUB HOUSE ROAD  
BEACH MOUNTAIN, NC, 28604