



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12163-52-4564
State Number
21707

EQUIPMENT INSPECTED

State Number: 21707	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: OTIS	Speed: 125
Landings: 3	Installed: 05/20/2003	Rope Size: 0
Volts: 208	Complied: 05/21/2003	Entrances: 1
OWNER	OCCUPANT	
DIAMOND CREEK, LLC	DIAMOND CREEK CLUBHOUSE	
P.O. BOX 2216	1552 DOBBINS ROAD	
BANNER ELK, NC, 28604	BANNER ELK, NC, 28604	

INSPECTION INFORMATION

Inspection Date 06/11/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 52 - Sosebee	County AVERY
-------------------------------	----------------------------	---------------------------------	---------------------------	-----------------

6

VIOLATIONS

- 8.11.2.3 Perform a 5 year load and safety test according to the applicable codes, and provide a metal tag upon completion in its proper place or location.
8.6.1.7.2 Provide the proper metal tag on the controller for all periodic tests.

Items must be corrected by: 07/11/2012

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Ed Shell 828-898-1800

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

DIAMOND CREEK, LLC
P.O. BOX 2216
BANNER ELK, NC, 28604