N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12164-17-4364
State Number
22348

EQUIPMENT INSPECTED

State Number: **22348**
Capacity: 2500
Landings: 2
Volts: 208

Type of Unit: Passenger
Manuf: AEC
Installed: 04/30/2004
Complied: 04/30/2004

Floor to Floor: 1 to 2
Speed: 100
Rope Size: 0
Entrances: 1

OWNER
ALAN'S PAWN
1186 PATTON AVE.
ASHEVILLE, NC, 28806

OCCUPANT
ALAN'S PAWN
1186 PATTON AVE.
ASHEVILLE, NC, 28806

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
06/12/2012	Routine	Re-issued	17 - White	BUNCOMBE	11 A

VIOLATIONS

8.11.3	Perform the 5 year full load test on pit valve.
note	Annual smoke detector test due June 2012.

Items must be corrected by: 07/12/2012

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Ron 828-254-8681 Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
ALAN'S PAWN
1186 PATTON AVE.
ASHEVILLE, NC, 28806