



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12178-48-1442
State Number
H402

EQUIPMENT INSPECTED

State Number: H402	Type of Unit: Hand Lift	Floor to Floor: 1 to 2
Capacity: 500	Manuf: STAIRGLIDE	Speed: 10
Landings: 2	Installed: 07/01/1991	Rope Size:
Volts: 120	Complied: 07/01/1991	Entrances: 2
OWNER	OCCUPANT	
SOLDIER BAY BAPTIST CHURCH	SOLDIER BAY BAPTIST CHURCH	
PO BOX 10	HWY 130	
ASH, NC, 28420	ASH, NC, 28420	

INSPECTION INFORMATION

Inspection Date 06/26/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.14.1.4.5 Put the in car stop switch in proper working order. ALSO LOBBY STOP SW.

Items must be corrected by: 07/26/2012

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: PASTOR SMITH

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SOLDIER BAY BAPTIST CHURCH
PO BOX 10
ASH, NC, 28420