



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12184-24-5767
State Number
21596

EQUIPMENT INSPECTED

State Number: 21596	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: ASHEVILLE	Speed: 95
Landings: 2	Installed: 08/14/2003	Rope Size: 0
Volts: 480	Complied: 08/14/2003	Entrances: 1

OWNER

ASHEVILLE CHRISTIAN ACADEMY
PO BOX 1089
SWANNANOVA, NC, 28778

OCCUPANT

ASHEVILLE CHRISTIAN ACADEMY
74 RIVERWOOD ROAD
SWANNANOVA, NC, 28778

INSPECTION INFORMATION

Inspection Date 07/02/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 24 - Moore	County BUNCOMBE	11 B
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

- 2.13.5.1 Put the car door reopening devices in proper working order. Sensor times out at 45 secs and closes door with no reopening. Must have a buzzer and reduced speed to operate this way.
- 2.27.1.1.2 Put the in car emergency telephone in proper working order. Replace the missing door handle on the phonebox door.
- 2.11.3.1 Adjust the elevator hoistway doors to self close fully. 2nd floor door sticks mid-point of close.

Items must be corrected by: 08/01/2012

Elevator Name: ELEVATOR WEST

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Mark Brant / 828-545-8234

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ASHEVILLE CHRISTIAN ACADEMY
PO BOX 1089
SWANNANOVA, NC, 28778