

## N C Department of Labor Elevator Bureau 1101 Mail Service Center, Raleigh, NC 27699-1101

## INSPECTION REPORT

IMPORTANT: Always use State Number in any correspondence relating to your equipment www.nclabor.com/elevator.htm 919-707-7927

Report Number 12185-36-2975 State Number 26515

1

		EQUIPMENT INSPECTED		
State Number: 26515 Capacity: 3000 Landings: 2 Volts: 208	Type of Unit: Passenger Manuf: OTIS Installed: 07/20/2009 Complied: OCCUPANT BUCKNER COMPANIES HOME OFF 4734 NC HWY 54 GRAHAM, NC, 27253		Floor to Floor: 1 to 2 Speed: 100 Rope Size: Entrances: 1	
OWNER BUCKNER COMPANIES P O BOX 598 GRAHAM, NC, 27253				
	n	NSPECTION INFORMATION		
Inspection Date 07/03/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
		VIOLATIONS		
8.6.1.7.2 A metal tag with the be readily visible an	e applicable code requirement(s) and descurely attached to the controller	d date(s) performed, and the name of each unit for all periodic tests	e of the person or firm perform.	ing the test, shall be installed to
Items must be corrected by				
complainace with current codes		n when the following corrections		
Violations pointed out to: GEN			Inspector	
THIS IS NOT AN INVOICE	To make changes to the invoice real An invoice will be mailed to:	nailing address please call: 919-7 BUCKNER COMPANIE P O BOX 598 GRAHAM NC. 27253		