



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12185-36-4845
State Number
18886

EQUIPMENT INSPECTED

State Number: 18886	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2000	Manuf: CANTON	Speed: 100
Landings: 3	Installed: 01/29/2001	Rope Size:
Volts: 208	Complied: 01/29/2001	Entrances: 1
OWNER		OCCUPANT
EP GATES CONST & REALTY		PARIS BLDG
PO BOX 872 JENNIFER TALLEY 336-2294		28 NW COURT SQ
GRAHAM, NC, 27253		GRAHAM, NC, 27253

INSPECTION INFORMATION

Inspection Date 07/03/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

none found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: ENNIFER TALLEY 336-2294

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

EP GATES CONST & REALTY
PO BOX 872 JENNIFER TALLEY 336-2294
GRAHAM, NC, 27253