



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12193-16-2536
State Number
24438

EQUIPMENT INSPECTED

State Number: **24438**

Capacity: 2500

Landings: 4

Volts: 230

Type of Unit: Passenger

Manuf: TKE

Installed: 01/10/2007

Complied: 01/10/2007

Floor to Floor: P to 3

Speed: 125

Rope Size: 0

Entrances: 2

OWNER

DAY BEACON HOA

PO BOX 1303

MANTEO, NC, 27954

OCCUPANT

DAY BEACON

326 E WATER STREET

BELLHAVEN, NC, 27810

INSPECTION INFORMATION

Inspection Date
07/11/2012

Type Inspection
Routine

Certificate Status
Not Issued

Inspector
16 - Moore

County
BEAUFORT

7

VIOLATIONS

8.6.4.15 Take steps to place the car emergency telephone in proper working order.
Could not get in Machine room

Elevator Name: C

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Nathan / Maintenance

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

DAY BEACON HOA
PO BOX 1303
MANTEO, NC, 27954