



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12198-52-3780
State Number
21513

EQUIPMENT INSPECTED

State Number: 21513	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: OTIS	Speed: 125
Landings: 3	Installed: 08/06/2003	Rope Size: 0
Volts: 208	Complied: 08/12/2003	Entrances: 1
OWNER	OCCUPANT	
BANNER ELK PRESBYTERIAN	BANNER ELK PRESBYTERIAN	
PO BOX 158	420 COLLEGE DRIVE	
BANNER ELK, NC, 28604	BANNER ELK, NC, 28604	

INSPECTION INFORMATION

Inspection Date 07/16/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 52 - Sosebee	County AVERY
-------------------------------	----------------------------	---------------------------------	---------------------------	-----------------

6

VIOLATIONS

2.14.7.1.3	Put the in car emergency light in working order.
2.11.11.8	Install the missing door retainers where needed. (2nd landing hoistway door missing bottom fire tabs.)
2.27.1.1.2	Put the in car emergency telephone in proper working order.
8.11.3.2.1	Perform the annual relief valve test.
8.6.1.7.2	Provide the proper metal tag to the controller for all periodic test.
8.6.5.16.5	Perform the 5 year full load test on the overspeed valve.

Items must be corrected by: 08/15/2012

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Banner Elk Presbyterian 828-387-2258

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BANNER ELK PRESBYTERIAN
PO BOX 158
BANNER ELK, NC, 28604