



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12198-52-5757
State Number
8962

EQUIPMENT INSPECTED

State Number: 8962	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 06/02/1977	Rope Size: 0
Volts: 220	Complied: 06/02/1977	Entrances: 1
OWNER	OCCUPANT	
ESEECOLA LODGE	ESEECOLA LODGE CLUBHOUSE	
P.O BOX 99	83 ROSEBORO ROAD	
LINVILLE, NC, 28646	LINVILLE, NC, 28646	

INSPECTION INFORMATION

Inspection Date 07/16/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 52 - Sosebee	County AVERY
-------------------------------	----------------------------	---------------------------------	---------------------------	-----------------

6

VIOLATIONS

2.27.1.1.2	Put the in car emergency telephone in proper working order.
8.6.4.8.4	Take steps to keep the machine room access door locked at all times.
NEC	Install the missing cover on the electrical box in the machine room.
NEC	All electrical wiring shall be in approved conduit and / or boxes from the point it enters machine room.

Items must be corrected by: 08/15/2012

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Eseecola Lodge Clubhouse 828-733-4311

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ESEECOLA LODGE
P.O BOX 99
LINVILLE, NC, 28646