



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12200-8-5515
State Number
9763

EQUIPMENT INSPECTED

State Number: 9763	Type of Unit: Freight	Floor to Floor: 1 to 3
Capacity: 6000	Manuf: SOUTHERN	Speed: 100
Landings: 3	Installed: 10/22/1980	Rope Size:
Volts: 220	Complied: 10/22/2004	Entrances: 1

OWNER

WADE MANUFACTURING CO.
P.O.BOX 32
WADESBORO, NC, 28170

OCCUPANT

WADE MANUFACTURING CO.
HIGHWAY 74 EAST
WADESBORO, NC, 28170

INSPECTION INFORMATION

Inspection Date 07/18/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 8 - Burris	County ANSON
-------------------------------	----------------------------	---------------------------------	-------------------------	-----------------

4

VIOLATIONS

8.11.1.2 PERFORM ANNUAL PRESSURE RELIEF VALVE TEST

Elevator Name: SHOP ELEVATOR

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: REP- KENNETH GREENE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

WADE MANUFACTURING CO.
P.O.BOX 32
WADESBORO, NC, 28170