



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12205-8-2288
State Number
14303

EQUIPMENT INSPECTED

State Number: 14303	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 3	Installed: 02/21/1991	Rope Size:
Volts: 230	Complied: 02/21/1991	Entrances: 1
OWNER	OCCUPANT	
FIRST UNITED METHODIST CHURCH	FIRST UNITED METHODIST CHURCH	
118 E MORGAN ST	118 E MORGAN ST	
WADESBORO, NC, 28170	WADESBORO, NC, 28170	

INSPECTION INFORMATION

Inspection Date 07/23/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 8 - Burris	County ANSON
-------------------------------	----------------------------	---------------------------------	-------------------------	-----------------

4

VIOLATIONS

NONE

Elevator Name: PASSENGER ELEV

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: REP- BETTY CRAWFORD

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

FIRST UNITED METHODIST CHURCH
118 E MORGAN ST
WADESBORO, NC, 28170